## JB22-2



Products Low Voltage Products and Systems Connection Devices Terminal Blocks Accessories Jumper Bars

General Information

Extended Product Type: JB22-2

Product ID: 1SNK922302R0000

EAN: 3472599163607

Catalog Description: JB22-2 Jumper Bar
Long Description: Screw jumper bars

## Additional Information

| ABB Industrial IT Suite:           | Control IT   |
|------------------------------------|--|
| ATEX Certificate:                  | 1SND162004A1707  |
| Ambient Air Temperature:           | Operation -55 +110 °C<br>Storage -55 +110 °C   |
| Ambient Temperature:               | -5 +40 °C  |
| CB Certificate:                    | 1SND161034A0202  |
| Country of Origin:                 | France (FR)  |
| Customs Tariff Number:             | 85369010   |
| Data Sheet, Technical Information: | 1SNK160033D0201  |
| Degree of Protection:              | acc. to IEC 60529, IEC 60947-1, EN 60529 Main Terminals IP20   |
| Dielectric Test Voltage:           | 2200 V   |
| E-nummer:                          | 2925393  |
| EAN:                               | 3472599163607  |
| ETIM 4:                            | EC000489 - Cross-connector for terminal block  |
| ETIM 5:                            | EC000489 - Cross-connector for terminal block  |
| ETIM 6:                            | EC000489 - Cross-connector for terminal block  |
| Function:                          | Jumper Bars  |
| IIT Publishing Status:             | Level 0 - Information enabled  |
| Industrial IT Certification Level: | 0  |
| Instructions and Manuals:          | 1SNK160027C0201  |
| Insulation Material:               | Polyamide  |
| Invoice Description:               | JB22-2 Jumper Bar  |
| Maximum Operating Voltage UL/CSA:  | Main Circuit 600 V   |
| Medium Description:                | Screw jumper bars  |
| Minimum Order Quantity:            | 5 piece  |
| Mounting Type:                     | <ul> <li>With flat pliers, cut out the partitions on the terminal block insulating body. Be careful to not<br/>cut out the jumpered terminal blocks partitions at both ends of the assembly in order to maint<br/>ain the IP20, Nema1 protection and insulation, - Install the jumper bar with the recommended<br/>tool and torque.</li> </ul> |
| Number of Poles:                   | 2  |
| Object Classification Code:        | X  |
| Order Multiple:                    | 5 piece  |
| Package Level 1 EAN:               | 3472599163607  |
| Package Level 1 Gross Weight:      | 0.135 kg   |
| Package Level 1 Height:            | 45 mm  |
| Package Level 1 Length:            | 105 mm   |
| Package Level 1 Units:             | 5 piece  |
| Package Level 1 Width:             | 45 mm  |
| Package Level 2 Gross Weight:      | 3.19 kg  |

|   | -  |
|---|--|
| Package Level 2 Height:   | 200 mm   |
| Package Level 2 Length:   | 300 mm   |
| Package Level 2 Units:  | 105 piece  |
| Package Level 2 Width:  | 200 mm   |
| Package Level 3 Units:  | 10080 piece  |
| Power Loss:   | 6.1 W  |
| Product Main Type:  | JB22   |
| Product Name:   | Jumper Bar   |
| Product Net Depth:  | 20.7 mm  |
| Product Net Height:   | 35 mm  |
| Product Net Length:   | 20.7 mm  |
| Product Net Weight:   | 27 g   |
| Product Net Width:  | 22 mm  |
|   |  |
| Product Packing Type:   | Box  |
| Product Packing Type:  Rated Current (I <sub>n</sub> ):   | Box Main Circuit 192 A   |
|   | <u> </u>   |
| Rated Current (I <sub>n</sub> ):  | Main Circuit 192 A   |
| Rated Current ( $I_n$ ):<br>Rated Impulse Withstand Voltage ( $U_{imp}$ ):  | Main Circuit 192 A<br>8000 V   |
| Rated Current ( $I_n$ ):<br>Rated Impulse Withstand Voltage ( $U_{imp}$ ):<br>Rated Short-time Withstand Current ( $I_{cw}$ ):  | Main Circuit 192 A<br>8000 V<br>for 1 s 8400 A   |
| Rated Current ( $I_n$ ): Rated Impulse Withstand Voltage ( $U_{imp}$ ): Rated Short-time Withstand Current ( $I_{cw}$ ): Rated Voltage ( $U_r$ ):   | Main Circuit 192 A  8000 V  for 1 s 8400 A  1000 V   |
| Rated Current (I <sub>n</sub> ): Rated Impulse Withstand Voltage (U <sub>imp</sub> ): Rated Short-time Withstand Current (I <sub>cw</sub> ): Rated Voltage (U <sub>r</sub> ): Recommended Screw Driver:   | Main Circuit 192 A 8000 V for 1 s 8400 A 1000 V 4 mm   |
| Rated Current (I <sub>n</sub> ): Rated Impulse Withstand Voltage (U <sub>imp</sub> ): Rated Short-time Withstand Current (I <sub>cw</sub> ): Rated Voltage (U <sub>r</sub> ): Recommended Screw Driver: RoHS Date:  | Main Circuit 192 A  8000 V  for 1 s 8400 A  1000 V  4 mm  18 08 2005   |
| Rated Current (I <sub>n</sub> ): Rated Impulse Withstand Voltage (U <sub>imp</sub> ): Rated Short-time Withstand Current (I <sub>cw</sub> ): Rated Voltage (U <sub>r</sub> ): Recommended Screw Driver: RoHS Date: RoHS Information:  | Main Circuit 192 A  8000 V  for 1 s 8400 A  1000 V  4 mm  18 08 2005  1SND230499F0202  |
| Rated Current (In): Rated Impulse Withstand Voltage (Uimp): Rated Short-time Withstand Current (Icw): Rated Voltage (Ur): Recommended Screw Driver: RoHS Date: RoHS Information: RoHS Status:   | Main Circuit 192 A  8000 V  for 1 s 8400 A  1000 V  4 mm  18 08 2005  1SND230499F0202  Following EU Directive 2002/95/EC August 18, 2005 and amendment                           |
| Rated Current (I <sub>n</sub> ): Rated Impulse Withstand Voltage (U <sub>imp</sub> ): Rated Short-time Withstand Current (I <sub>cw</sub> ): Rated Voltage (U <sub>r</sub> ): Recommended Screw Driver: RoHS Date: RoHS Information: RoHS Status: Selling Unit of Measure:                    | Main Circuit 192 A  8000 V  for 1 s 8400 A  1000 V  4 mm  18 08 2005  1SND230499F0202  Following EU Directive 2002/95/EC August 18, 2005 and amendment piece                     |
| Rated Current (I <sub>n</sub> ): Rated Impulse Withstand Voltage (U <sub>imp</sub> ): Rated Short-time Withstand Current (I <sub>cw</sub> ): Rated Voltage (U <sub>r</sub> ): Recommended Screw Driver: RoHS Date: RoHS Information: RoHS Status: Selling Unit of Measure: Short Description: | Main Circuit 192 A  8000 V  for 1 s 8400 A  1000 V  4 mm  18 08 2005  1SND230499F0202  Following EU Directive 2002/95/EC August 18, 2005 and amendment piece  Jumper Bars JB22-2 |



ZS70