

**PRODUCT-DETAILS** 

## CM-PVS.41S

## CM-PVS.41S Three-phase monitoring relay 2c/o, 0,0.1-30s, L1-L2-L3=3x300-500VAC



General Information	
Extended Product Type	CM-PVS.41S
Product ID	1SVR730794R3300
EAN	4016779851848
Catalog Description	CM-PVS.41S Three-phase monitoring relay 2c/o, 0,0.1-30s, L1-L2-L3=3x300-500VAC
Long Description	The CM-PVS.41S relay is from the CM three-phase monitors range. This relay operates with a rated control supply voltage / three-phase measuring voltage of 300-500 V AC and has a 2 c/o output with contacts rated at 250 V / 4 A. The CM-PVS.41S monitors the phase parameters over/undervoltage and phase failure. The corresponding threshold values are adjustable. Phase sequence monitoring as well as an ON or OFF tripping delay are selectable. The tripping delay is adjustable over a range of instantaneous to 30 s (0, 0.1-30 s). A sealable transparent cover for protection against unauthorized changes is available as accessory. The device offers screw connection technology with double-chamber cage connection terminals.

Ordering	
EAN	4016779851848
Minimum Order Quantity	1 piece
Customs Tariff Number	85364900

## Popular Downloads

Data Sheet, Technical Information

2CDC112211D0201

CM-PVS.41S 2

Instructions and Manuals	1SVC730730M1000 1SVC730730M0000
CAD Dimensional	2CDC001079B0201

Dimensions	
Product Net Width	22.5 mm
Product Net Height	85.6 mm
Product Net Depth / Length	103.7 mm
Product Net Weight	0.139 kg

Technical	
Function	Phase failure detection
	Phase sequence monitoring Over- and undervoltage monitoring
Measuring Range	(L-L) 300 500 V AC
Time Range	200 ms start-up delay
	0 s or 0.1 30 s tripping delay (ON or OFF)
Rated Control Supply Voltage (U <sub>s</sub> )	(L-L) 300 500 V AC
Rated Frequency (f)	Supply Circuit 50/60 Hz
Output	2 c/o (SPDT) contacts
Terminal Type	Screw Terminals
Rated Operational Current AC-12 (I <sub>e</sub> )	(230 V) 4 A
Rated Operational Current AC-15 (I <sub>e</sub> )	(230 V) 3 A
Rated Operational Current DC-12 ( $I_e$ )	(24 V) 4 A
Rated Operational Current DC-13 ( $I_e$ )	(24 V) 2 A
Minimum Switching Capacity	24 V 10 mA
Rated Impulse Withstand Voltage (U <sub>imp</sub> )	Input Circuit 6 kV Output Circuit 4 kV
Rated Insulation Voltage $(U_i)$	Input Circuit / Output Circuit 600 V Output Circuit 1 / Output Circuit 2 300 V
Degree of Protection	Housing IP50 Terminals IP20
Overvoltage Category	III
Pollution Degree	3
Short-Circuit Protective Devices	Output Circuit NC - F Type Fuses 6 A Output Circuit NO - F Type Fuses 10 A
Electrical Durability	AC-12 100000 cycle
Mechanical Durability	30000000 cycle
Connecting Capacity	Flexible with Ferrule 1x 0.5 2.5 mm² Flexible with Ferrule 2x 0.5 1.5 mm² Flexible with Insulated Ferrule 1x 0.5 2.5 mm² Flexible with Insulated Ferrule 2x 0.5 1.5 mm² Flexible 1x 0.5 2.5 mm² Flexible 2x 0.5 1.5 mm² Rigid 1x 0.5 4 mm² Rigid 2x 0.5 2.5 mm²
Tightening Torque	0.6 0.8 N·m
Wire Stripping Length	8 mm
Recommended Screw Driver	0.8 x 4 4.5 Pozidriv 1
Mounting Position	1 6
Mounting on DIN Rail	TH35-15 (35 x 15 mm Mounting Rail) acc. to IEC 60715

Standards

TH35-7.5 (35 x 7.5 mm Mounting Rail) acc. to IEC 60715 CAN/CSA C22.2 No.14 IEC/EN 63000 IEC/EN 60255-27 IEC/EN 61000-6-2 IEC/EN 61000-6-3 UL 508

Maximum Operating Voltage UL/CSA	Output Circuit 300 V AC
Contact Rating UL/CSA	B300
Connecting Capacity UL/CSA	Flexible 1x 18-14 AWG Flexible 2x 18-16 AWG Rigid 1x 20-12 AWG Rigid 2x 20-14 AWG
Tightening Torque UL/CSA	7.08 in lb
Pilot Duty UL/CSA	B300
Flammability According to UL94	V-C
Environmental	
Ambient Air Temperature	Operation -25 +60 °C Storage -40 +85 °C
Maximum Operating Altitude Permissible	Without Derating 2000 m
REACH Declaration	No declaration needed
RoHS Information	1SVD981014-00
Circular Value	
Circular Value End of Life Instructions	1SAC200290H0001
End of Life Instructions	1SAC200290H0001
End of Life Instructions  Certificates and Declarations	
End of Life Instructions  Certificates and Declarations  CQC Certificate	CQC2009010303326655
Certificates and Declarations  CQC Certificate cULus Certificate Declaration of Conformity	
Certificates and Declarations  CQC Certificate cULus Certificate Declaration of Conformity - CCC Declaration of Conformity	CQC2009010303326655 cULus508_20120829-E140448
Certificates and Declarations  CQC Certificate cULus Certificate Declaration of Conformity - CCC Declaration of Conformity - CE Declaration of Conformity	CQC2009010303326655 cULus508_20120829-E140448 2020980303000197 1SVD981014-00
	CQC2009010303326655 cULus508_20120829-E140448 2020980303000197 1SVD981014-00 1SVD981014-10
Certificates and Declarations  CQC Certificate cULus Certificate Declaration of Conformity - CCC Declaration of Conformity - CE Declaration of Conformity - UKCA	CQC2009010303326655 cULus508_20120829-E140448 2020980303000197 1SVD981014-00 1SVD981014-10
Certificates and Declarations  CQC Certificate cULus Certificate Declaration of Conformity - CCC Declaration of Conformity - CE Declaration of Conformity - UKCA DNV GL Certificate	CQC2009010303326655 cULus508_20120829-E140448 2020980303000197
Certificates and Declarations  CQC Certificate cULus Certificate Declaration of Conformity - CCC Declaration of Conformity - CE Declaration of Conformity - UKCA DNV GL Certificate EAC Certificate	CQC2009010303326655 cULus508_20120829-E140448 2020980303000197 1SVD981014-00 1SVD981014-10 DNV_GL_TAA000017D EAC_RU_C-DE.ME77.B.03424
Certificates and Declarations  CQC Certificate cULus Certificate Declaration of Conformity - CCC Declaration of Conformity - CE Declaration of Conformity - UKCA DNV GL Certificate  EAC Certificate  Container Information  Package Level 1 Units Package Level 1 Width	CQC2009010303326655 cULus508_20120829-E140448 2020980303000197 1SVD981014-00 1SVD981014-10 DNV_GL_TAA000017D EAC_RU_C-DE.ME77.B.03424
Certificates and Declarations  CQC Certificate cULus Certificate Declaration of Conformity - CCC Declaration of Conformity - CE Declaration of Conformity - UKCA DNV GL Certificate EAC Certificate  Container Information Package Level 1 Units	CQC2009010303326655 cULus508_20120829-E140448 2020980303000197 1SVD981014-00 1SVD981014-10

Package Level 1 Height

Package Level 1 Gross

Package Level 1 EAN

Weight

109 mm

0.164 kg

4016779851848

CM-PVS.41S 4

Classifications	
Object Classification Code	В
ETIM 7	EC001441 - Phase monitoring relay
ETIM 8	EC001441 - Phase monitoring relay
ETIM 9	EC001441 - Phase monitoring relay
eClass	V11.0 : 27371803
UNSPSC	39122332
E-Number (Finland)	2712294
E-Number (Sweden)	3860584

## Categories

 $Low\ Voltage\ Products\ \rightarrow\ Control\ Products\ \rightarrow\ Electronic\ Relays\ and\ Controls\ \rightarrow\ Three\ Phase\ Monitors$ 

