

PRODUCT-DETAILS

## CM-PVS.31S CM-PVS.31S Three-phase monitoring relay 2c/o, 0,0.1-30s, L1-L2-L3=3x160-300VAC



Extended Product Type	CM-PVS.31
Product ID	1SVR730794R130
EAN	401677985183
Catalog Description	CM-PVS.31S Three-phase monitoring relay 2c/o, 0,0.1-30s, L1-L2-L3=3x160-300VAC
Long Description	The CM-PVS.31S relay is from the CM three-phase monitors range. This relay operates with a rated control supply voltage / three-phase measuring voltage of 160-300 V AC and has a c/o output with contacts rated at 250 V / 4 A. The CM-PVS.31S monitors the phase parameters over/undervoltage and phase failure. The corresponding threshold values are adjustable. Phase sequence monitoring as well as an ON or OFF tripping delay are selectable. The tripping delay is adjustable over a range of instantaneous to 30 s (0, 0.1-30 s). A sealable transparent cover for protection against unauthorized changes is available as
Ordering	
Ordering EAN	accessory. The device offers screw connection technology with double-chamber cage connection terminals 401677985183:
<u> </u>	connection terminals
EAN	401677985183
EAN Minimum Order Quantity	401677985183 1 piece

© 2024 ABB. All rights reserved.

2024/01/11

Subject to change without notice

Dimensions

Instructions and Manuals	1SVC730730M1000 1SVC730730M0000
CAD Dimensional Drawing	2CDC001079B0201

Product Net Width	22.5 mm
Product Net Height	85.6 mm
Product Net Depth / Length	103.7 mm
Product Net Weight	0.141 kg
Technical	
Function	Phase failure detection Phase sequence monitoring Over- and undervoltage monitoring
Measuring Range	(L-L) 160 300 V AC
Time Range	200 ms start-up delay 0 s or 0.1 30 s tripping delay (ON or OFF)
Rated Control Supply Voltage (U <sub>s</sub> )	(L-L) 160 300 V AC
Rated Frequency (f)	Supply Circuit 50/60 Hz
Output	2 c/o (SPDT) contacts
Terminal Type	Screw Terminals
Rated Operational Current AC-12 (I <sub>e</sub> )	(230 V) 4 A
Rated Operational Current AC-15 (I <sub>e</sub> )	(230 V) 3 A
Rated Operational Current DC-12 (I <sub>e</sub> )	(24 V) 4 A
Rated Operational Current DC-13 (I <sub>e</sub> )	(24 V) 2 A
Minimum Switching Capacity	24 V 10 mA
Rated Impulse Withstand Voltage (U <sub>imp</sub> )	Input Circuit 6 kV Output Circuit 4 kV
Rated Insulation Voltage $(U_i)$	Input Circuit / Output Circuit 600 V Output Circuit 1 / Output Circuit 2 300 V
Degree of Protection	Housing IP50 Terminals IP20
Overvoltage Category	III
Pollution Degree	3
Short-Circuit Protective Devices	Output Circuit NC - F Type Fuses 6 A Output Circuit NO - F Type Fuses 10 A
Electrical Durability	AC-12 100000 cycle
Mechanical Durability	3000000 cycle
Connecting Capacity	Flexible with Ferrule 1x 0.5 2.5 mm² Flexible with Ferrule 2x 0.5 1.5 mm² Flexible with Insulated Ferrule 1x 0.5 2.5 mm² Flexible with Insulated Ferrule 2x 0.5 1.5 mm² Flexible 1x 0.5 2.5 mm² Flexible 2x 0.5 1.5 mm² Rigid 1x 0.5 2 fmm² Rigid 2x 0.5 2 fmm²
Tightening Torque	0.6 0.8 N·m
Wire Stripping Length	8 mm
Recommended Screw Driver	0.8 x 4 4.5 Pozidriv 1
Mounting Position	16
Mounting on DIN Rail	TH35-15 (35 x 15 mm Mounting Rail) acc. to IEC 60715

Mounting on DIN Rail

TH35-15 (35 x 15 mm Mounting Rail) acc. to IEC 60715

© 2024 ABB. All rights reserved.

2024/01/11

Subject to change without notice

Standards

Technical UL/CSA	
Maximum Operating Voltage UL/CSA	Output Circuit 300 V AC
Contact Rating UL/CSA	B30
Connecting Capacity UL/CSA	Flexible 1x 18-14 AWG Flexible 2x 18-16 AWG Rigid 1x 20-12 AWG Rigid 2x 20-14 AWG
Tightening Torque UL/CSA	7.08 in It
Pilot Duty UL/CSA	B300
Flammability According to UL94	V-(
Environmental	
Ambient Air Temperature	Operation -25 +60 °C Storage -40 +85 °C
Maximum Operating Altitude Permissible	Without Derating 2000 m
REACH Declaration	No declaration needed
RoHS Information	1SVD981014-00
RoHS Status	Following EU Directive 2011/65/EL
Certificates and Declarations	
CQC Certificate	CQC2009010303326655
cULus Certificate	cULus508_20120829-E140448
Declaration of Conformity - CCC	2020980303000197
	1SVD981014-00
- CE Declaration of Conformity	
- CE Declaration of Conformity	1SVD981014-10
- UKCA	1SVD981014-10 DNV_GL_TAA000017E
- CE Declaration of Conformity - UKCA DNV GL Certificate	1SVD981014-10 DNV_GL_TAA000017E
- CE Declaration of Conformity - UKCA DNV GL Certificate EAC Certificate Container Information	1SVD981014-10 DNV_GL_TAA000017E EAC_RU_C-DE.ME77.B.03424
- CE Declaration of Conformity - UKCA DNV GL Certificate EAC Certificate	1SVD981014-10 DNV_GL_TAA000017E EAC_RU_C-DE.ME77.B.03424 box 1 piece
- CE Declaration of Conformity - UKCA DNV GL Certificate EAC Certificate Container Information Package Level 1 Units	1SVD981014-10 DNV_GL_TAA000017E EAC_RU_C-DE.ME77.B.03424 box 1 piece 97 mm
- CE Declaration of Conformity - UKCA DNV GL Certificate EAC Certificate Container Information Package Level 1 Units Package Level 1 Units Package Level 1 Depth / Length Package Level 1 Height	1SVD981014-10 DNV_GL_TAA000017E EAC_RU_C-DE.ME77.B.03424 box 1 piece 97 mm 30 mm 109 mm
- CE Declaration of Conformity - UKCA DNV GL Certificate EAC Certificate Container Information Package Level 1 Units Package Level 1 Units Package Level 1 Depth / Length Package Level 1 Depth / Length Package Level 1 Height Package Level 1 Gross Weight	1SVD981014-10 DNV_GL_TAA000017E EAC_RU_C-DE.ME77.B.03424 box 1 piece 97 mm 30 mm 109 mm 0.166 kg
- CE Declaration of Conformity - UKCA DNV GL Certificate EAC Certificate Container Information Package Level 1 Units Package Level 1 Depth / Length Package Level 1 Depth / Length Package Level 1 Height Package Level 1 Gross	1SVD981014-00 1SVD981014-10 DNV_GL_TAA000017D EAC_RU_C-DE.ME77.B.03424 box 1 piece 97 mm 30 mm 0.166 kg 4016779851831

© 2024 ABB. All rights reserved.

2024/01/11

Subject to change without notice

Classifications		
Object Classification Code	В	
ETIM 7	EC001441 - Phase monitoring relay	
ETIM 8	EC001441 - Phase monitoring relay	
ETIM 9	EC001441 - Phase monitoring relay	
eClass	V11.0 : 27371803	
UNSPSC	39122332	
E-Number (Finland)	2712292	
E-Number (Sweden)	3860583	

## Categories

 $\text{Low Voltage Products and Systems} \rightarrow \text{Control Products} \rightarrow \text{Electronic Relays and Controls} \rightarrow \text{Three Phase Monitors}$ 

